



# Greenhouse Engineering

86 Glenview Avenue, Toronto, Ontario M4R 1P8, Canada  
Tel: (416) 489 3816 Fax: (416) 481 3883

## NCERA – 101 Committee on Controlled Environment Technology and Use

### 2008 International Meeting on Controlled Environment Agriculture

March 8 - 12  
Kennedy Space Center  
Florida

# **Performance Verification of New Research Greenhouse Facilities**

**Alex Turkewitsch\*, MAsc, P.Eng., Greenhouse Engineering,  
David Brault, MSc, MGP, Ing., Greenhouse Engineering,  
Bruno Faucher, MSc, MEnv, Ing., EnviroSult, 570,**

Commissioning new greenhouses involves confirming that all the systems function properly and meet the performance requirements in the specifications.

Our specifications for greenhouse air tightness generally call for a maximum infiltration rate with a minimum wind speed and a defined interior and exterior temperature.

Example: 0.75 air changes per hour @ 20 °C interior and 0 °C and wind > 15 km/h.

Testing can be done by means of tracer gas dilution measurement (ASTM E741-95) with CO<sub>2</sub>.

PROBLEM 1: Wind velocity at commissioning is different than the conditions in the specifications.

PROBLEM 2: Outdoor and indoor temperatures can vary significantly. The resulting temperature difference ( $\Delta T$ ) also result in non standard conditions.


PROPOSED SOLUTION: Determine appropriate correction factors to apply to infiltration rates measured with varying wind and  $\Delta T$  conditions to normalize the results to “standard specification conditions”.

Greenhouse Engineering undertook the design, construction phase services of a major new facility at Université Laval in Quebec city. Commissioning was performed by GHE and the greenhouse contractor in January of 2008.

With the permission and collaboration of the University we carried out repeated air infiltration tests under varying wind and temperature conditions in order to acquire sufficient data to establish normalization factors.



Photo: B. Faucher 2008



SECTION DÉTAILLÉE — DETAILED CROSS SECTION 1/8 (H6)



1. LE RELEVÉ DE TRAVAIL A ÉTÉ RÉVISÉ ET APPROUVÉ PAR LE BUREAU D'INGÉNIERIE GÉNÉRALISTE. 2. LE RELEVÉ DE TRAVAIL A ÉTÉ RÉVISÉ ET APPROUVÉ PAR LE BUREAU D'INGÉNIERIE GÉNÉRALISTE. 3. LE RELEVÉ DE TRAVAIL A ÉTÉ RÉVISÉ ET APPROUVÉ PAR LE BUREAU D'INGÉNIERIE GÉNÉRALISTE. 4. LE RELEVÉ DE TRAVAIL A ÉTÉ RÉVISÉ ET APPROUVÉ PAR LE BUREAU D'INGÉNIERIE GÉNÉRALISTE.

NO	DESCRIPTION	DATE
1	PROJET	2011-01-01
2	REVISION	2011-01-15
3	REVISION	2011-02-01
4	REVISION	2011-02-15
5	REVISION	2011-03-01
6	REVISION	2011-03-15
7	REVISION	2011-04-01
8	REVISION	2011-04-15
9	REVISION	2011-05-01
10	REVISION	2011-05-15

SERRES / GREENHOUSES

NO	DESCRIPTION	DATE
1	PROJET	2011-01-01
2	REVISION	2011-01-15
3	REVISION	2011-02-01
4	REVISION	2011-02-15
5	REVISION	2011-03-01
6	REVISION	2011-03-15
7	REVISION	2011-04-01
8	REVISION	2011-04-15
9	REVISION	2011-05-01
10	REVISION	2011-05-15















# OBJECTIVE

Determine normalization factors for infiltration measurements under varying wind and  $\Delta T$  conditions.

# METHODOLOGY

## The greenhouse

- Greenhouse compartment: 20ft x 25ft with 16ft gutter height,
- South-West corner of greenhouse wing,
- No plants were present during the tests,
- No venting, no cooling,
- Internal destratification fans (VAF) always running.



Wind: SW →

↑  
Wind: SE



# METHODOLOGY


## Dilution Tracer Gas Dilution Testing with CO<sub>2</sub>

Testing was automated with the Priva control system, on a continuous basis from February 21<sup>st</sup> to February 26<sup>th</sup>.


- Every 6 hours CO<sub>2</sub> was injected from a liquid bottle equipped with a pressure regulating valve and a solenoid controlled by the Priva system.
- Injection time was ten (10) minutes, increasing the compartment concentration to ~ 2000 μmol.mol<sup>-1</sup>.
- readings were taken every five (5) minutes for six (6) hours and consisted of;
  - CO<sub>2</sub> concentration (μmol.mol<sup>-1</sup>),
  - Indoor temperature (°C),
  - Outdoor temperature (°C),
  - Wind speed (m/s).







# RESULTS





# RESULTS

- Total number of data sets logged, (CO<sub>2</sub>, interior, exterior temperature and wind speed), raw data: 1722.
- 604 data sets were rejected (due to injecting periods, abnormal readings due to user errors)

# ANALYSIS

The infiltration rate (S) is expressed as

$$S = (3600 t^{-1}) \ln \left\{ \frac{(C_{\text{Start}} - C_{\text{Ambient}})}{(C_{\text{End}} - C_{\text{Ambient}})} \right\},$$

where

t = test duration (s),

S = infiltration rate ( $\text{h}^{-1}$ ),


$C_{\text{Start}}$  =  $\text{CO}_2$  concentration at the beginning of the test ( $\mu\text{mol}\cdot\text{mol}^{-1}$ ),

$C_{\text{End}}$  =  $\text{CO}_2$  concentration at the end of the test ( $\mu\text{mol}\cdot\text{mol}^{-1}$ ),


$C_{\text{Ambient}}$  =  $\text{CO}_2$  concentration of the ambient air ( $\mu\text{mol}\cdot\text{mol}^{-1}$ ).

Ref: ASTM, E-741-95

Infiltration rate and wind speed (m/s) vs time (raw data)




Infiltration rate and delta T (C) vs time






### 80 infiltration points frequency




### 87 infiltration points frequency






Infiltration rate vs delta T-(feb-21 to feb-26)



# MODEL



$$P_w = \frac{C_p \rho_o V^2}{2}$$

$$P_s = \frac{\rho_o g (T_o - T_i)}{T_i} (H_{NPL} - H)$$

$P_s$  = net stack pressure (Pa)

$P_w$  = pressure exerted by the wind (Pa)

$V$  = wind speed (m/s)

$\rho_o$  = outside air density (Kg/m<sup>3</sup>)

$C_p$  = wind pressure coefficient (ref. NGMA)

$T_o, T_i$  = outside and inside air temperatures (°K)

$H_{NPL}$  = distance of the Neutral Pressure Level (m) from reference

$H$  = distance to Neutral Pressure (m) Level

$g = 9.8 \text{ m/s}^2$



# MODEL

The total pressure,  $\Delta P$ , driving infiltration will be the sum of the wind pressure and the stack effect:

$$\Delta P = P_w - P_s = \frac{C_p \rho V^2}{2} + \rho_o g \frac{(T_o - T_i)}{T_i} (H_{NPL} - H)$$

The fluid equation for flow complex openings is can be expressed as :

$$Q = C A_e \sqrt{2\rho} \Delta P^n$$

$C$  = flow coefficient

$A_e$  = effective area of the orifice


$n$  = flow exponent varies from 0.5 (turbulent) to 1 (laminar)

Combining:


$$Q = C * A_e * \sqrt{2\rho} \left\{ \frac{C_p \rho V^2}{2} + \rho_o g \frac{\Delta T}{T_i} (H_{NPL} - H) \right\}^n$$

# Model Results

# Pressure vs Wind



# Theoretical Resultant Pressure vs Delta T



# CONCLUSIONS

- Wind and stack effects are not additive linearly.
- Wind and stack effects interact, even to the extent of negative contribution.
- For moderate temperature differentials (15 C - 30 C), infiltration rate and wind speed are not strongly correlated.
- At moderate wind speed (4.5 m/s), infiltration rate is insensitive to the full range of temperature differentials measured and predicted.
- The model developed does not yet match the experimental results.
- However, both model and experimental results confirm unexpected interactions between wind and stack effects.

# RECOMMENDATIONS

- The model should be extended to different configurations of greenhouse.
- Further measurements, especially those at lower and positive temperature differentials, should be made.
- Further measurements in different structures should be made.
- A more extensive literature review is required.
- The specification requirements for infiltration testing should be changed to allow for either wind or stack effects but not both simultaneously.



- Dr. Jean Caron,  
Université Laval  
Québec,  
Canada



Les Industries Harnois inc

- Marco Rondeau,  
controls technician

Thank you

**ghe**

**Greenhouse Engineering**

86 Glenview Avenue, Toronto, Ontario M4R 1P8, Canada

Tel: (416) 489 3816

Fax: (416) 481 3883